

<b>Technical Information</b>	Date: 28.01.2016 Official: Marier Department.: ST-FIR/MKP3
------------------------------	--

<b>Tech. Information No.</b>	1977 / 2016
<b>Subject:</b>	FPA-5000 new software: MPC V2.16.5, FSP-5000-RPS V4.5.6 and FSI/OPC Server V1.3.5

<b>Short Description:</b>	RPS compatibility with Windows 10, PAVIRO included, minor fixes
---------------------------	---

<b>Hardware</b> <input type="checkbox"/>	<input type="checkbox"/> Device	<input type="checkbox"/> Module	<input type="checkbox"/> PCBA
<b>Software</b> <input checked="" type="checkbox"/>	<input checked="" type="checkbox"/> Application	<input type="checkbox"/> Driver / Extension	<input checked="" type="checkbox"/> Firmware

Affected Products (details)	CTN	SAP no.	Aff. version	New version
FPA-5000 panel controller	MPC-xxxx-B		2.15.3	2.16.5
FPA-5000 panel controller	MPC-xxxx-C		2.15.3	2.16.5
FPA-1200 panel controller	FPA-1200-MPC		2.15.3	2.16.5
FPA-1200 panel controller	FPA-1200-MPC-C		2.15.3	2.16.5
FMR-5000 keypad	FMR-5000-xx		2.15.3	2.16.5
FMR-5000 keypad	FMR-5000-C		2.15.3	2.16.5
FPA-OPC-Server	FPA5000OPCServer		1.3.4	1.3.5
FPA Fire System Interface	FSM5000FSI		1.3.4	1.3.5
FPA-5000 configuration tool	FSP-5000-RPS	F.01U.005.615	4.4.5	4.5.6

<b>Number of delivered devices</b>	
<b>Period of delivery</b>	from: to:
<b>Affected serial numbers</b>	from: to:

Priority Level	Criterion
I <input type="checkbox"/>	The change has to be made <b>immediately</b> (see dates below)
II <input type="checkbox"/>	The change has to be made during the next inspection.
III <input checked="" type="checkbox"/>	Change has to be made, if the error pattern recurs and with new installations.
None <input type="checkbox"/>	General Information (like new tool, new feature, new SW release)

Action Plan	
<input checked="" type="checkbox"/>	Inform customers
<input type="checkbox"/>	Arrange re-work of stock (NSO)
<input type="checkbox"/>	Arrange re-work of stock (customer)
<input type="checkbox"/>	Arrange re-work of installed products
<input type="checkbox"/>	See detailed actions on following pages

<b>Start Date</b>		<b>Completion Date</b>	
-------------------	--	------------------------	--

Error(s) and Effect(s)
<p>New features:</p> <ul style="list-style-type: none"> <li>a) Released RPS now compatible with Windows 10 64bit</li> <li>b) Released PAVIRO voice alarm system to be used as VAS over IP</li> <li>c) Remote Maintenance prepared (configurable in RPS, data is sent to Remote Portal)</li> </ul> <p>Fixed:</p> <ul style="list-style-type: none"> <li>a) PAS: A PAS-alarm, bypassed during investigation time (e.g. via BMS), could lead to a true alarm after a new PAS-alarm is triggered.</li> <li>b) FAS-420-TT - If info alarm appears during walktest, info alarm is sent to FSI instead of walktest-normal.</li> <li>c) 'Remote Connect': Transmission of configuration data upload/download interrupted when inactive for more than 15 minutes.</li> </ul>

Cause

Action(s)
<p><a href="#">Download new releases</a> from global training platform</p> <p>Note: Please consider that the current "Fire Monitoring System FSM-2500/FSM-5000" release V5.0.1, based on FSM-5000-FSI V1.3.4, requires an update in order to be compatible with the MPC V2.16.5. The updated version of "Fire Monitoring System FSM-2500/FSM-5000" will be released soon.</p>

Required Components	Part no.

Attachment(s)

<b>BU Manager</b>	Knauel	<b>Clerk in Charge:</b>	Marier
-------------------	--------	-------------------------	--------

**Distribution**

Distribution BU FIR	<input checked="" type="checkbox"/> Celebi Guenay (ST-FIR/QMM), Knauel Thomas (ST-FIR/MKP ST-FIR/MKT), Heckl Michael (ST-FIR/MKP3) <input checked="" type="checkbox"/> Angstenberger Josef (ST-FIR/MKR-EU) <input checked="" type="checkbox"/> Lim Yong Gang (ST/SRM-AP), Leonard Hew (ST-FIR/MKR-AP), Quek Daniel (ST-CO/MKR2-AP) <input checked="" type="checkbox"/> Squarize Alex (ST/SRM-LA), Pinto Erik (ST/STS-LA ST-ASA/SRA-LA), Render Chelsea (ST/SRM-NA) <input type="checkbox"/>
Distribution BU IN	<input type="checkbox"/> Hossmann Daniela (ST-IN/MKR-EU), Kugler Gerhard (ST-IN/MKR2-EU), Endres Dirk (ST-IN/QMM) <input type="checkbox"/> Berberian Alexandra (ST-IN/MKR-SEF), Tantry Ananth (ST-IN/MKR-SEM), Karlsson Mathias (ST-IN/MKR-SEN), Rodriguez Herrero Jose Manuel (ST-IN/MKR-SEI), Oppab Maria (ST-IN/MKR-SAN), Malek Michal (ST/MKR-SEP) <input type="checkbox"/> Mechler Tom (ST-IN/MKR-NA) <input type="checkbox"/>
Distribution BU ESS	<input type="checkbox"/> Loh Leon (ST-ESS/MKP1.4), Maier Holger (ST-ESS/MKP1.2), Wings Maarten (ST-ESS/MKP1.3), Redeker Bernd (ST-ESS/QMM), Jan von Rosenstiel (ST-ESS/MKP1.1), Reinhard Bloss (ST-ESS/MKP1) <input type="checkbox"/> Funke Thomas (ST-ESS/ENG) <input type="checkbox"/> Nikolas Mangold-Takao (ST-ESS/MKP1), Jaco Liebetrau (ST-ESS/MKT) <input checked="" type="checkbox"/> Markus Brack (ST-ESS/MKP2.3), Huse Istvan (ST/PRM2-EU), Law Jeffrey (ST/PRM1-AP) <input type="checkbox"/> Gary Deng (ST-PRM-CN), James Judson (ST-IN/MKR-NA) <input type="checkbox"/>
Other parties affected	<input checked="" type="checkbox"/> Steidle Kurt (ST-ASA/PRM1) <input checked="" type="checkbox"/> Proyer Konrad (ST-ASA/SRA-EU), Schrimpf Felix (ST-ASA/PRM), Wilson Jim (ST-ASA/SRA-AM), Tan Woo Khiang (ST/ASA-AP) <input type="checkbox"/> Pedolzky Georg (ST-BT/PRM1) <input type="checkbox"/> <input type="checkbox"/>