

EN 54-13:2017

EN 54-13:2017

Executive summary

In May 2017 the revised EN 54-13:2017 was released.

In this revised norm the requirements on "**creeping open/short**" were **dropped**.

The market specific consequences are shown on the following pages.

EN 54-13:2017

Market specific consequences

1. All countries without demand for EN 54-13:

No changes.

2. All markets except Germany with demand for EN 54-13:

Field element installations are now simplified:

- no EOL modules required anymore
- TI module instead of TI13 module for FPP-5000 is sufficient
- AUX outputs of all interface modules (e. g. FLM-420/4-CON) can now be used
- stub topology for notification appliances possible (instead of ring topology)

For further details please consult the wiring guide for the FPA-5000 V12.7 (currently in draft).

EN 54-13:2017

German market

